



XCFR8.E158377 - TERMINAL BLOCKS CERTIFIED FOR CANADA - COMPONENT

Terminal Blocks Certified for Canada - Component

See General Information for Terminal Blocks Certified for Canada - Component

NHD INDUSTRIAL CO LTD
 47 LANE 268 HSIN SHU RD
 HSIN-CHUANG, TAIPEI HSIEN 242 TAIWAN

E158377

Cat. No.	Wire Range	Wire Type	TQ N-M	V	A	UG	CA
HT-2.5	22-12 SOL/STR	CU	0.6	600	20	B,C,D	2(105),4
HT-4	22-10, STR 22, SOL	CU	5	600	30(1)	B,C,D	2(105),4
HT-10	22-10, SOL/STR 8, STR	CU	10	600	50(2)	B,C,D	2(105),4
HT-16	12, SOL/STR10, SOL	CU	20	300	20	B,C	2(105),4
	12, SOL/STR10 SOL	CU	20	600	20	D	2(105),4
HT-16E#	10 SOL/STR	CU	2.9	600	—	B,C,D	2(105),4
HT-35	12, SOL/STR14, SOL	CU	25	600	20	B,C,D	2(105),4
HT-50	6-1/0, STR	CU	30	600	150	B,C,D	2(105),4
HT-95	2, SOL/STR	CU	5.1	600	115	B,C,D	2(105),4
HTP-4	22-10, SOL	CU	—	600	30	B,C,D	2(105),4
HT-4E#	10-22, SOL/STR	CU	5	600	—	B,C,D	2(105),4, #
HT-10E#	6-20, SOL/STR	CU	10	600	—	B,C,D	2(105),4, #
HT-35E#	10, SOL/STR	CU	25	600	—	B,C,D	2(105),4, #
NHT-2	14 STR	Cu	0.9	300	20	B, C	2(115), 5
	14 STR	Cu	0.9	600	20	D	2(115), 5
NHT-3.5	12 STR	Cu	1.7	300	30	B, C	2(115), 5
	12 STR	Cu	1.7	600	30	D	2(115), 5
NHT-8	8 STR	Cu	3.4	600	50	B, C, D	2(115), 5
NHT-14	6 STR	Cu	3.4	600	60	B, C, D	2(125), 5
NHT-22	4 STR	Cu	5.1	600	90	B, C, D	2(125), 5
NHT-38	2 STR	Cu	11.3	600	130	B, C, D	2(125), 5
NHT-60	6 STR	Cu	5.1	600	60	B, C, D	2(125), 5
NHT-100	2 STR	Cu	11.3	600	100	B, C, D	2(125), 5
NHT-200	4/0 STR	Cu	22.6	600	240	B, C, D	2(125), 5
NHT-400	500 or 500 x 2 STR	Cu	42.9	600	370	B, C, D	2(125), 5

#Unique Conditions of Acceptability - Has been evaluated for its suitability as a protective conductor terminal block and complies with the applicable grounding requirements for terminals for use in a protective circuit. (General Industrial Application)

- (1) - 30A maximum for factory wiring only wire sizes 12-22 AWG.
- (2) - 50A maximum for factory wiring only.

Marking: Company name or trademark "NHD" and Recognized Component Mark for Canada, , on the product. Catalog designation, maximum voltage, wire range, and ampere rating appear on the device or, in or on the carton.

Last Updated on 2008-11-20

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"